

Fire Door Annual Inspection

Understanding the Fire-Rated Opening









Foundation's Mission:

Promote secure and safe openings that enhance life safety

The Foundation & DHI

Door Security&Safety FOUNDATION

> First to create awareness for fire door inspections.



 Set the standard for education that qualifies individuals as the knowledgeable resource to perform fire door inspections.

- Not Familiar with Code Requirements
- Belief that frequency of use ensures proper operation



Annual Inspection of Fire Door Assemblies...

- Who Is Going To Do These Inspections and When?
 - Paragraph 5-2.3, Functional Testing
 - Individuals who are KNOWLEDGEABLE about the openings being inspected
 - Paragraph 5-2.1, '...not less than annually, and a written record of the inspection shall be kept for inspection by the AHJ.'

Partial List of IFC 2009 Adoption

- Alabama (IBC, IFC)
- California (IBC, IFC)
- Colorado (Denver)
- Illinois (IBC, IFC)
- Iowa (IBC, IFC)
- Massachusetts (IBC)
- Maine (IBC,IFC local)
- Maryland (IBC)
- Michigan (IBC,IFC local)

IFC 2009 Adoption

- Montana (IBC, IFC local)
- New Hampshire (IBC,IFC local)
- New Jersey (IBC)
- New Mexico (IBC)
- New York (New York Building Codes)
- North Dakota (IBC,IFC local)
- Oregon (IBC, IFC)
- Oklahoma (not statewide)
- Pennsylvania (IBC, IFC)
- Rhode Island (IBC, IFC- local)
- South Dakota (not statewide)


IFC 2009 Adoption

- Utah (IBC, IFC)
- Virginia (IBC, IFC)
- West Virginia (IBC, IFC local)
- Washington (IBC, IFC)

Guam (IBC '09, no IFC listing)

Ohio - IFC 2006


Ohio - ICC Explained.doc



Door Security & Safety Foundation

MGM Grand – Nov. 11th, 1980 Las Vegas – 85 killed, 700 injured






Fire Doors Performing as Designed





Fire Doors Performing as Designed



Properly Closed Fire Door







Codes vs. Standards

- Codes are Intended to be Adopted as Legal Documents
 - Enforceable as Laws
- Standards are Intended to be Used to Meet the Requirements of Codes
 - Unenforceable until REFERENCED by a CODE.

NFPA 80 – 2007 Edition


- Establishes Basic Requirements for New Fire-Rated Door Assemblies
- Establishes Care and Maintenance Requirements



NFPA 80 2007— Standard for Fire Doors


5.2.4.2 As a <u>minimum</u>, the following items shall be verified:

- (1) No open holes or breaks exist in surfaces.
- (2) Glazing, vision light frames, and glazing beads are intact.
- (3) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order.
- (4) No parts are missing or broken.
- (5) Door clearances do not exceed the clearances listed.




NFPA 80 2007— Standard for Fire Doors

- 5.2.4.2 As a <u>minimum</u>, the following items shall be verified:
 - (6) The self-closing device is operational
 - (7) If a coordinator is installed, the inactive leaf closes before active leaf. (pairs only)
 - (8) Latching hardware operates and secures the door when it is in the closed position.



NFPA 80 2007— Standard for Fire Doors

- 5.2.4.2 As a <u>minimum</u>, the following items shall be verified:
 - (9) Auxiliary hardware items that interfere or prohibit operation are not installed.
 - (10) No field modifications to the door have been performed.
 - (11) Gasketing and edge seals are inspected.




Fire Door Inspection— Background

 Fire Doors are governed by the building code and NFPA throughout design, specification, installation and occupancy permitting.







IFC 2009—703.1.3


• Fire walls, fire barriers and fire partitions. Required fire walls, fire barriers and fire partitions shall be:



- Maintained to prevent the passage of fire.
- All openings protected with approved doors and fire dampers shall be maintained in accordance with NFPA 80.

Fire Door Inspection—IBC


 The International Building Code is used until the certificate of occupancy is issued.






Fire Door Inspection—NFPA 101

 7.2.1.15.2 – Fire-rated door assemblies shall be inspected and tested in accordance with NFPA 80, Standard for Fire Doors and Other Opening Protectives.









Existing Fire Doors Today



Heat Release Mechanism

Existing Fire Doors Today



Confused?



NFPA 80—Chapter 4 General Requirements

Fire Door Assemblies

 Prepared for Hardware Under Door/Frame Manufacturer's Inspection Service Procedure and Under Label Service [4.1.3.1]

Listed and Labeled Products

 Listed items shall be identified by a label, which is readily visible to AHJ. [4.2]

NFPA 80—Chapter 4

- What Modifications Can Be Done in the Field?
 - Function Holes for Mortise Locks/Latches
 - Holes for Labeled Door Viewers
 - Round Holes for Surface Applied Hardware (up to 1" in Diameter)
 - Throughbolts
 - Wood/Composite Doors Trimmed to Maximum 3/4" Undercutting
 - [4.1.3.2, 4.1.3.3 and 4.1.3.4]

NFPA 80—Chapter 4

Field Modifications that CAN NOT be done in the field:

Doors

- No Vision Panel Cut Outs
- No Louver Cut Outs
- No Mortise Lock Pockets
- No Face or Edge Bores for Bored Locks
- No Mortise Hinge Preparations

Frames

- No Mortise Hinge Preparations
- No Cut Outs

NFPA 80—Chapter 4

- Clearances Under Doors
 - Swinging Doors with Builders Hardware
 - Maximum Clearance of 3/4" Under Door Bottom
 - [4.8.4.1]

NFPA 80—Chapter 6

- Builders Hardware Consists of:
 - Hinges & Pivots
 - Door Bolts
 - Locks or Latches
 - Fire Exit Hardware (a.k.a. Exit Devices)
 - Door Closers
 - Protection Plates
 - Astragals
 - Gasketing

Fire Resistance Classifications

Hourly Ratings

```
1/3 = 20-Minutes

3/4 = 45-Minutes

1 = 60-Minutes (Wood Doors)

1-1/2 = 90-Minutes

3 = 180-Minutes
```

Note: This information is listed under Annex D. "Fire Doors and Fire Window Classifications." The hourly designation indicates duration of the fire test exposure. It is known as the fire protection rating.

Fire Labels for Frames















Fire Labels for Doors
















Criteria Listed on Label





Label Placement

Label should be attached to the hinge edge of the door.



Glass Label (Permanent etching, per NFPA 80)








Annual Inspection Requirements—NFPA 80


Swinging Doors with Builders Hardware



Chapter 5 Care & Maintenance

 5.1.1.2 The requirements of this chapter shall apply to <u>new and</u> <u>existing</u> installations.





Chapter 5 Care & Maintenance

5.2.1* Fire door assemblies shall be inspected and tested not less than annually, and a written record of the inspection shall be signed and kept for Inspection by the AHJ.

Chapter 5 Care & Maintenance

5.2.3.1 Functional testing of fire door and window assemblies shall be **performed by individuals with knowledge and understanding** of the operating components of the type of door being subject to testing.



Annual Inspection of Fire Door Assemblies

What Do Inspectors Need to Know?

- Immense product application and installation knowledge
 - Hollow metal doors and frames
 - Wood fire doors
 - Builders Hardware Application
- Thorough understanding of NFPA 80 requirements
- Benchmark Fire Door Assembly Inspector (FDAI) program.
- Years of industry experience to qualify for prereq for AHC and/or CDC.

Annual Inspection of Fire Door Assemblies


- Inspector's Responsibilities:
 - Status of door openings on date of inspection
 - Recommend necessary corrections
 - Providing written inspection reports

Annual Inspection of Fire Door Assemblies

- Inspectors Are Not Responsible For:
 - Making sure openings are repaired
 - Determining the correct fire-rating of door openings
 - Alerting AHJ of problems


Chapter 5 Care & Maintenance

- 5.2.2 Performance-Based Option
- 5.2.2.1 As an alternate means of compliance with 5.2.1, subject to the AHJ, fire door assemblies shall be permitted to be inspected, tested, and maintained under a written, performance-based program.




NFPA 80 2007— Standard for Fire Doors Chapter 5 Care & Maintenance

- 5.2.2 Performance-Based Option.
- 5.2.2.2 Goals established under a performance-based program shall provide assurance that the fire door assembly will perform its intended function when exposed to fire conditions.
- 5.2.2.3 Technical justification for inspection, testing, and maintenance intervals shall be documented.



NFPA 80 2007— Standard for Fire Doors Chapter 5 Care & Maintenance

- 5.2.2 Performance-Based Option.
- 5.2.2.4 The performance-based option shall include historical data acceptable to the AHJ.



MGM Grand Hotel Fire Door Inspection

Example. Without Performance-Based Option

- January 1st Two inspectors start inspecting doors.
 - Each inspector works 40 hours a week for a full year.
- December 31st All doors have been inspected.
- January 1st Start all over again.



Preparing for the Inspection









Identifying Fire Door Assemblies

- Maintenance personnel—access to the 'as built' floor plans.
- AHJ's office archived copies of floor plans
- No plans available—should physically check each door opening looking for labels.

Locating Fire Doors in Buildings

- Interior doors opening into and out of stairwells and corridors.
- Door openings placed at building separations.
- Identify fire labels on frame and hinge side of door.

Performing the Inspections

- Presumption of Correct Application
- Original Building, Fire and Life Safety Code Requirements
- Practical Application of Inspection Criteria

Original Building, Fire, and Life Safety Requirements

- Inspectors should be cognizant of the building, fire and life safety codes that were applicable at the time of installation.
- Should not apply the capabilities, limitations and requirements for modern products to assemblies installed years ago.
- NFPA 80 standard is applicable to all existing fire door assemblies, regardless of when they were installed.

Cataloging Fire Doors

- Door Number (Code or Symbol)
- Location of Assembly in Building
- Type of Door Assembly
- Fire-Protection Rating
- Comments/Remarks

Inspection Summary Report Form

INSPECTION SUMMARY	Date of Inspection, 2008
REPORT 2008	Inspector Information
BUILDING NAME	A Program of the Door and Herdware Institute Name: ID Number Exp. Date:
	Inspecting Company Information
ADDRESS	Name:
	Address:
SUMMARY	
	da
Form for compliance with the requirements of NFPA 80 2007 Edition; Section 5.2 as of t	fire door assemblies existing on the date of the inspection and identified on this inspection the time of the inspection, and that inspector is not inspecting any other openings in the
Company and any other person or entity for any and all injuries, claims, losses, expense	by agree that, to the fullest extent permitted by law, the total liability of Inspector, Inspecting as or damages whatsoever arising out of or in any way related to the inspection from any breach of contractor breach of warranty shall not exceed the total amount of the inspection
fee. The Door and Hardware Institute ("DHI") assumes no liability for the conduct of the release DHI from all liability related thereto or arising therefrom.	e Inspector, Inspecting Company or others or the inspection, and the undersigned hereby OFFICIAL USE ONLY
	(funert Sua) or Stump)
SIGNATURES	

FDAI Inspection Report

FIRE-RATED	SWINGING	DOOR
INSPECTION	SURVEY 2	800

COMMENTS



Pg. _____ of ____

BUILDING NAME

Door Number	Compliant	Non-Compliance Code(s)* (Please use codes found on back of this sheet as a general guide)
	DYES DINO	
	COYES CONO	
	QYES QNO	
	DYES DINO	
	OYES ONO	
	QYES QNO	
	QYES QNO	
	DYES DNO	
	COYES CONO	
	COYES CONO	
	DYES DINO	
	DYES DNO	
	DYES DINO	
	QYES QNO	
	COYES CONO	
	QYES QNO	

Door Security & Safety Foundation

FDAI Code Violations Defined

Please use the following codes to identify problems on the door apprings listed on other side of page

				-	OR ROLLS	FID	E EVE HADDWADE	-	00.01.00500		OF LANEOUS
30.00	ME		OR (cont.)	DO	OR BOLTS	23(3)	E EXIT HARDWARE	DO	OR CLOSERS	MIS	CELLANEOUS
F1 F2 F3 F4 F5 F6 F7 F8 F9 F10	Modification (Explain Modification) Incorrect Hardware	D14 D18	3 Unused Fastener Hole(s) in Door(s) 4 Improper Plant-ons 5 Replace Door 6 Other	B1 B2 B3 B4 B5 B6 B7 B8 B9 B10	Missing Top Flush Bolt Missing Bottom Flush Bolt Missing Strike (Top Bolt) Missing Strike (Bottom Bolt) Bottom Bolt does NOT Engage Strike Missing Bolt Head (Top) Missing Bolt Head (Bottom) Missing Rub Plate(s) Incorrect Type of Flush Bolt(s) Other	E1 E2 E3 E4 E5 E6 E7 E8 E9 E10 E11	Missing Fire Exit Device Missing Latch Bolt Assembly (Top) Missing Latch Bolt Assembly (Bottom) Missing Strike(s) Missing Vertical Rod (Top) Missing Vertical Rod (Bottom) Push Bar Does NOT Extend Halfway Across Door Width Non-fire Rated Panic Hardware (Dogging) Missing Lever or Knob Missing Scraw(s) Missing Sex Nuts and	C12	Missing Carry Bar		Missing Threshold/ Saddle Incorrect Clearance (Top of Door to Frame) Incorrect Clearance (Hinge Edge to Frame) Incorrect Clearance (Lock Edge to Frame) Incorrect Clearance (Door Bottom to Floor) Incorrect Clearance (Between Doors) Missing or Damaged Gasketing/Smoke Seal Kick-down Door Holder Door Wedge Door Stop with Hold
F12	Preparation (Explain) Unused Fastener Hole(s) in Frame	T4	Electric Door Release Does NOT Allow Door to Close		4		Missing Sex Nuts and Bolts Mullion	C15	Other		Open (Manual) Protection Plate(s)
	Other	T5 T6 T7 T8	Door Bottom Drags Against Floor Material Door Rubs Against Frame Edges of Paired Doors Overlap Coordinator Does NOT	L1 L2 L3	Missing Lock Incorrect Latch Bolt Throw Non-fire Rated Latch Bolt	E13	Other			M14 M15	too Large Protection Plate(s) Missing screw(s) Signage Too Large Signage, Screwed/ Nailed to Door
DO	OR		Function Properly	L4	Latch Bolt Binds					M16	Other
D1 D2 D3 D4 D5	Missing Door(s) Missing Label Damaged Door(s) (e.g., Dented, Bent) Rust-through on Door(s) Delamination of Door Skin or Face	T9	Other	L5 L6 L7 L8 L9	Latch Bolt Missing Loose Lever(s) or Knob(s) Latch Bolt Does NOT Engage Strike Missing Strike Plate Missing Screw(s)						***************************************
D6	Incorrect Glass in	414	FR. 11. 11.	1.40	Missing Ekish Bolt						



L10 Missing Flush Bolt

L12 Other _

L11 Missing Flush Bolt Strike

Missing Hinge(s)

Loose Hinge(s)

D7 Broken Glass in Light(s)

D8 Light(s) is/are Too Large

D9 Loose Light Kits

D10 Missing Light Kit Screw(s) D11 Improper Field Modification (Explain Modification) D12 Incorrect Hardware

Incorrect Hinge(s)

Missing Screw(s)

Replace Hinge(s)



Items to be Verified During Fire Door Inspection










Three Main Operational Requirements


- Swinging Fire-Doors with Builders Hardware Must:
 - Swing Freely
 - Be self or automatic-closing or power-operated
 - Positively latch when in the closed position.

5.2.4.2 As a <u>minimum</u>, the following items shall be verified:


- (1) No open holes or breaks exist in surfaces.
- (2) Glazing, vision light frames, and glazing beads are intact.
- (3) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order.
- (4) No parts are missing or broken.
- (5) Door clearances do not exceed the clearances listed.



- 5.2.4.2 As a <u>minimum</u>, the following items shall be verified:
 - (6) The self-closing device is operational
 - (7) If a coordinator is installed, the inactive leaf closes before active leaf. (pairs only)
 - (8) Latching hardware operates and secures the door when it is in the closed position.



- 5.2.4.2 As a <u>minimum</u>, the following items shall be verified:
 - (9) Auxiliary hardware items that interfere or prohibit operation are not installed.
 - (10) No field modifications to the door have been performed.
 - (11) Gasketing and edge seals are inspected.



Campus Fire Safety Right-to-Know Act

- Language included in this legislation that addresses fire doors
- Fire safety system: Any mechanism or system related to the detection of a fire, the warning resulting from a fire, or the control of a fire including:
 - Fire doors and walls that reduce the spread of a fire (required to be reported)

NFPA 80— Annual Fire Door Inspection Foundation-Published Guides



- AHJ Guide and Owner's Guide
- Reference Guide for Inspecting Swinging Fire Doors with Builders Hardware




- www.doorsecuritysafety.org
 - PDF of steps for simple inspection.

Summary

- Not possible to list all of the applications of doors, frames and builders hardware products for swinging fire door assemblies.
- Covered the most commonly used products to give you, the AHJ, GUIDELINES on how to accurately evaluate the operating condition of swinging fire door assemblies.

Summary

- Many swinging fire door assemblies can be:
 - Complicated.
 - Contain sophisticated hardware products.
 - These assemblies require a high-level of expertise to coordinate their functions with their fireprotection properties.



Door Security & Safety Foundation

Summary

- New fire-rated products are:
 - Continually being developed.
 - Requiring inspectors to stay current on their knowledge and understanding of these products' applications, capabilities and limitations.

Continued Focus

- Foundation offerings in partnership with strategic partners
 - One-day classroom training session
 - Based on DAI200 Class
 - Two & four hour awareness class
 - Introductory webinars
 - Online training module
 - Correspondence with state fire marshals offices
- Promoting local champion
- Healthcare, colleges, GSA, hospitality

For More Information Contact:





Phone: (703) 222-2010; Fax: (703) 222-2410

www.doorsecuritysafety.org www.dhi.org

All of the material in these slides remains the property of the Door Security & Safety Foundation and is copyright protected.